

ALL ISOLATIONS SHALL COMPLY WITH VUL-SOP-078-ISOLATION AND TAGGING

LOCKOUT STATION NUMBER:			
A Group Isolation Permit is used to isolate plant or equipment and provide a safe work area for the people involved. This Group Isolation Permit is to be used: - where more than one isolation point is required in order for a group of persons to conduct work; - when the isolation requirements are complicated and/or overlapping from shift to shift; and - when individuals are not able to competently carry out their own isolation.			
DESCRIPTION OF EQUIPMENT TO BE ISOLATED UNDER THIS PERMIT and WHY			
ISOLATION PRIOR TO COMMENCEMENT OF WORK			
1. The complex isolator confirms the plant or equipment to be isolated with the operations controller/shift supervisor and conducts a handover. 2. The complex isolator identifies all energy sources and isolation points, then completes the permit details below. 3. The complex isolator isolates, and releases stored energies, then applies Group Lock and Permit Danger Tags. 4. The complex isolator tests to confirm the effectiveness of the isolation.			
Identified Isolation Point	Group Lock #	Lock and Tag Applied (complex isolator initial to verify)	Lock and Tag Removed (complex isolator initial on removal)
Total # of Group Locks Applied:			
Complex Isolator Name:		Signature:	

[illegible]

TRANSFER OF GROUP ISOLATION PERMIT				
Outgoing Complex Isolator (Handover of Permit, Personal Lock and Tag removed)		Oncoming Complex Isolator (Acceptance of Permit, Personal Lock and Tag applied)		
Sign	Date/Time	Name	Sign	Date/Time
RESTORATION 7. Complex Isolator ensures all personnel have removed their Personal Danger Lock and Tag from the Group Lock Box and signed off this permit prior to removing their own Personal Danger Lock and Tag. Complex Isolator removes all Group Locks from the identified Isolation Points and acknowledges the removal below.				
Total # of Group Locks Removed:				
Complex Isolator Name:		Signature:		
CANCELLATION OF GROUP ISLOATION PERMIT <i>Statement by complex isolator:</i> <i>I hereby, cancel this isolation and acknowledge that I have:</i>				
	<i>Confirmed that all persons have removed their Personal Danger Locks and Tags from the Group Lock Box, and signed off this permit.</i>			
	<i>Verified that the equipment is safe to operate relative to the work carried out under this permit.</i>			
	<i>Confirmed that all Group Locks and Permit Danger Tags associated with this permit have been removed.</i>			
	<i>Confirmed any manual belt clamps that may have been fitted are removed.</i>			
	<i>Where plant or equipment is unable to be returned to service, applied an Out of Service Tag on the relevant equipment Isolation Point.</i>			
Name		Signature	Date	Time
8. Complex isolator notifies shift supervisor that the plant or equipment's isolation is complete, equipment is serviceable (or tagged Out of Service) and conducts handover.				